



Defence Infrastructure Organisation

██████████
Department of Energy & Climate Change
National Infrastructure Consents Team
4th Floor, Area 4C
3 Whitehall Place
London
SW1A 2AW

Safeguarding Department
Statutory & Offshore

Defence Infrastructure Organisation
Kingston Road
Sutton Coldfield
West Midlands
B75 7RL

Tel: +44 (0)121 311 ██████████ Tel (MOD): ██████████
Fax: +44 (0)121 311 ██████████
E-mail: DIO-safeguarding-statutory@mod.uk
www.mod.uk/DIO

Your Reference: N/K
Our reference: 10035683

13 April 2016

Dear ██████████

MOD Safeguarding – SITE OUTSIDE SAFEGUARDING AREA

Proposal: Variation of Electricity Act Consent for the Keadby ii CCGT Plant

Location: Ealand Road, Keadby, North Lincolnshire

Grid Ref: 482833, 411699

Thank you for consulting the Defence Infrastructure Organisation (DIO) on the above proposed development. This application relates to a site outside of Ministry of Defence (MOD) statutory safeguarding areas. We can therefore confirm that the MOD has no safeguarding objections to this proposal.

Whilst we have no safeguarding concerns with the proposed development, we request that if any structures such as flue stacks or chimneys are to exceed 50 metres AGL that they be charted and fitted with aviation warning lighting.

In the interests of air safety, the MOD requests that the structure is fitted with aviation warning lighting. The mast should be fitted with a minimum intensity 25 candela omni directional flashing red light or equivalent infra-red light fitted at the highest practicable point of the structure.

The height of the development will necessitate that aeronautical charts and mapping records are amended. Defence Infrastructure Organisation (DIO) Safeguarding therefore requests that, as a condition of any planning permission granted, the developer must notify UK DVOF & Powerlines at the Defence Geographic Centre with the following information prior to development commencing:

- a. Precise location of development.
- b. Date of commencement of construction.
- c. Date of completion of construction.
- d. The height above ground level of the tallest structure.
- e. The maximum extension height of any construction equipment.
- f. Details of aviation warning lighting fitted to the structure(s)

You can e-mail this information to the Defence Geographic Centre to dvof@mod.uk, or post it to:

D-UKDVOF & Power Lines
Geospatial Air Information Team
Defence Geographic Centre
DGIA
Elmwood Avenue
Feltham
Middlesex
TW13 7AH

I trust this adequately explains our position on this matter, however should you have any questions regarding this matter please do not hesitate to contact me.

Yours sincerely

A rectangular area of the document is completely blacked out, obscuring the signature of the sender.Two lines of text are redacted with black bars. The first line is a short bar, and the second line is a longer bar, likely covering a phone number and an email address.